

Written Quiz

- | | <u>POINTS</u> |
|---|----------------------|
| 1. The manufacturers label needs to be clearly visible and legible so that the user can easily determine _____, _____, and _____. | <u>30</u> |
| 2. The 4 basic intervals of maintenance are 1) _____, 2) _____, 3) _____, and 4) _____. | <u>30</u> |
| 3. The pressure gauge should be checked to determine _____. | <u>20</u> |
| 4. Hydrostatic testing for CO2 extinguishers is performed every _____ years, Halon extinguishers are tested every _____ years. | <u>20</u> |

POINTS POSSIBLE: 100

POINTS DEDUCTED:

FINAL SCORE:

Written Quiz - Key

	<u>POINTS</u>
1. The manufacturers label needs to be clearly visible and legible so that the user can easily determine OPERATING INSTRUCTIONS, RATING, and APPROPRIATE APPLICATIONS.	<u>30</u>
2. The 4 basic intervals of maintenance are 1) ANNUALLY , 2) AFTER EACH USE , 3) WHEN THERE IS EVIDENCE OF DAMAGE OR TAMPERING , and 4) WHEN EXPOSED TO ABNORMAL CONDITIONS.	<u>30</u>
3. The pressure gauge should be checked to determine WHETHER EXTINGUISHER HAS BEEN DISCHARGED OR PHYSICALLY DAMAGED.	<u>20</u>
4. Hydrostatic testing for CO2 extinguishers is performed every 5 years, Halon extinguishers are tested every 12 years.	<u>20</u>

POINTS POSSIBLE: 100

POINTS DEDUCTED:

FINAL SCORE: